

(Published in the *Washington County News* on December 10, 2009)

ORDINANCE NO. 735

AN ORDINANCE CONCERNING THE REGULATION OF ABOVEGROUND STATIONARY LIQUIFIED PETROLEUM GAS STORAGE TANKS IN THE CITY OF WASHINGTON, KANSAS.

BE IT ORDAINED BY THE GOVERNING BODY OF THE CITY OF WASHINGTON, KANSAS:

SECTION 1. All liquefied petroleum gas storage tanks and the use thereof are prohibited within the city limits of Washington, Kansas.

SECTION 2. This prohibition shall not apply to tanks forty (40) pounds or less in size.

SECTION 3. This prohibition shall not apply to the use of standard heating tanks used by construction companies and contractors for temporary installation on a building site. This use shall be limited to a period not to exceed forty-five (45) days and must be approved by the Fire Chief prior to use.

SECTION 4. Upon proper application and for good cause and exception shown, the Governing Body may grant a conditional use permit to locate a generally prohibited storage tank under conditions that the Governing Body may prescribe.

SECTION 5. This ordinance shall be effective upon its adoption and publication in the *Washington County News*.

PASSED BY THE CITY COUNCIL AND APPROVED BY THE MAYOR this 7th day of
December, 2009.

THE CITY OF WASHINGTON, KANSAS

(Seal)

Harold H. Jones, Jr., Mayor

ATTEST:

Denise M. Powell, City Clerk